

# EARTHQUAKE SENSITIVE AUTOMATIC GAS SHUTOFF VALVE (ESV) CERTIFICATIONS

## 2019 California Plumbing Code, CCR, Title 24, Part 5

California Reference Standard 12-16-1

ANSI/ASCE/SEI 25-16

### DSA CERTIFICATION DATE

Jan. 23, 2020

### MANUFACTURER

Pacific Seismic Products

233 East Avenue H-8

Lancaster, CA 93535

[www.4gasoff.net](http://www.4gasoff.net)

### CONTACT

Erik Waite

(661) 942-4499

[erik@pspvalves.com](mailto:erik@pspvalves.com)

DSA Label ID	Valve Size	Pressure (PSI)	Model Number
19-S03	3/4" 1" 1 1/4" 1 1/2"	7 7 7 7	300 (H,VT,VB) 301 (H,VT,VB) 302 (H,VT,VB) 303 (H,VT,VB)
19-S04	3/4" 1" 1 1/4" 1 1/2"	60 60 60 60	310 (H,VT,VB) 311 (H,VT,VB) 312 (H,VT,VB) 313 (H,VT,VB)
19-S05	2" 3" 4" 2 1/2"	60 60 60 60	314 (H,VT,VB) 315 (H,VT,VB) 316 (H,VT,VB) 318 (H,VT,VB)
19-S06	2" 3" 2 1/2"	60 60 60	314F 315F 318F
19-S07	6" 8"	60 60	317F 316F 319F
19-E01	NA	NA	ES 510 Seismic Electrical Switch Assembly Only – valves certified by others
19-E02	NA	NA	400 Seismic Actuated Valve Only – all other components certified by others